

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	5
yellow sandstone	5	127
gray sandstone w/ shale streaks	126	262

Total Depth **262**

Casing: 7" pvc spline from -1' to 59'
4" pvc spline from 60' to 260'

Grout: bentonite from 0 to 59

Water from sandstone at 180' to 260'

Static level 43' below casing top which is 1' above GL

Remarks:

Owner Address: 23445 Duryea Dr Lakae Forest, CA

Address of well: 1200 Cox Lane

Add'l loc info: Lot: Subdivision:

Permit Date: April 3, 2024

Permit #: 087-04-2024

COMPANY Beanland, Glen

FARM Schuttz, Dee

DATE DRILLED April 20, 2024

NO.

ELEVATION '

COUNTY NO. 20826

LOCATION

LATITUDE 37.583056

LONGITUDE -88.896389

COUNTY Johnson

API# 1208720826 00

8-11S-3E