

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	35
sand & gravel	35	44
brown clay	44	63
limestone & shale	63	200

Total Depth **200**

Casing: 5" PVC from -1' to 64'

Grout: MUD from 0 to 64

Size hole below casing: 5"

Water from limestone at 64' to 200'

Static level 25' below casing top which is 2' above GL

Pumping level 100' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 100' on 11/30/1992, with a capacity of 10 gpm

Remarks: pump inst by others, well sealed 11/17/92

Owner Address: 37 W. 103 McDonald Dr. Elgin, IL

Location source: Location from permit

Permit Date: October 23, 1992

Permit #:

COMPANY Neeley, Harry C.

FARM Peddy, Gerald

DATE DRILLED October 24, 1992

NO. 2

ELEVATION 805' GL

COUNTY NO. 20725

LOCATION

LATITUDE 41.984211

LONGITUDE -88.341816

COUNTY Kane

API# 1208920725 00

5-40N-8E