

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	25
sand & gravel	25	80
shale	80	179
limestone	179	415

Total Depth **415**

Casing: 5" BLACK STEEL from 0' to 380'

Grout: CUTTINGS from 0 to 380

Size hole below casing: 5"

Water from limestone at 0' to 0'

Static level 350' below casing top which is 1' above GL

Pumping level 380' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 380' on , with a capacity of 10 gpm

Remarks: owner instucted to take sample

Owner Address: 0 N 251 Robins Winfield, IL

Add'l loc info: Lot: #37 Subdivision: Deer Run East
unit #4

Location source: Location from permit

Permit Date: June 7, 1985

Permit #: 118232

COMPANY Rob, Peter

FARM Peterson, Andrew

DATE DRILLED August 2, 1985

NO.

ELEVATION 0'

COUNTY NO. 26589

LOCATION

LATITUDE 41.951559

LONGITUDE -88.380458

COUNTY Kane

API# 1208926589 00

13-40N-7E