

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	30
sand & gravel	30	45
clay	45	200
shale	200	230
lime	230	355

Total Depth **355**

Casing: 5" BLACK STEELE from 0' to 230'

Grout: CUTTINGS from 0 to 230

Size hole below casing: 5"

Water from lime at 0' to 0'

Static level 300' below casing top which is 1' above GL

Pumping level 320' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 0' on , with a capacity of 10 gpm

Remarks: license to R. Wellendorf

Owner Address: 521 Cumberland Trail Elgin, IL

Add'l loc info: Lot: 6 Subdivision: Castle Knoll

Location source: Location from permit

Permit Date: November 21, 1986 **Permit #:** 128252

COMPANY Rob, Ronald

FARM Home Castle Builders

DATE DRILLED January 15, 1987 **NO.**

ELEVATION 0' **COUNTY NO.** 27327

LOCATION

LATITUDE 42.070638 **LONGITUDE** -88.379454

COUNTY Kane **API#** 1208927327 00 **35-42N-7E**