

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	65
sand & gravel	65	140

Total Depth **140**

Casing: 5" PVC SCHEDULE 80 from 0' to 130'

5" PVC SCREEN from 130' to 140'

Screen: 10' of 5" diameter 10 slot

Grout: BENTONITE/SLRY from 0 to 130

Size hole below casing: 5"

Water from gravel at 130' to 140'

Static level 90' below casing top which is 1' above GL

Pumping level 90' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 120' on 4/16/1993, with a capacity of 40 gpm

Owner Address: 6 N 679 Decatur Ave. St. Charles, IL

Add'l loc info: Lot: #1245-1254 Subdivision: Fox River Hts.

Location source: Location from permit

Permit Date: April 2, 1993

Permit #:

COMPANY Liberg, Thomas P.

FARM Hood, Larry

DATE DRILLED April 15, 1993

NO.

ELEVATION 0'

COUNTY NO. 30853

LOCATION

LATITUDE 41.964862

LONGITUDE -88.295585

COUNTY Kane

API# 1208930853 00

11-40N-8E