

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	120
sand & gravel	120	170

Total Depth **170**

Casing: 5" STEEL A53 from 0' to 160'

Grout: BENTONITE from 0 to 160

Size hole below casing: 5"

Water from gravel at 160' to 170'

Static level 60' below casing top which is 1' above GL

Pumping level 70' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 100' on 2/3/1997, with a capacity of 15 gpm

Owner Address: 38 W 710 Bonnie Court St. Charles, IL

Address of well: Bonnie Dr.

Add'l loc info: Lot: #16 Subdivision: Evans Glen

Location source: Location from permit

Permit Date: November 1, 1996

Permit #:

COMPANY Kerry, Charles

FARM Janecek Builders

DATE DRILLED January 31, 1997

NO.

ELEVATION 0'

COUNTY NO. 32097

LOCATION

LATITUDE 41.927137

LONGITUDE -88.370475

COUNTY Kane

API# 1208932097 00

19-40N-8E