

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
fill	0	20
gray clay	20	95
pink clay & gravel	95	120
gray clay & gravel	120	182
gravel	182	198

Total Depth **198**

Casing: 5" BLACK STEEL from 0' to 195'

Size hole below casing: 5"

Water from gravel at 195' to 198'

Static level 70' below casing top which is 1' above GL

Pumping level 120' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 168' on 6/1/1998, with a capacity of 10 gpm

Owner Address: 1705 Larson Ave. St. Charles, IL

Address of well: 40 W 400 Fair Oaks Dr. St. Charles, IL St. Charles
IL

Add'l loc info: Lot: #3 Subdivision: Willow Run

Location source: Location from permit

Permit Date: September 9, 1997 **Permit #:** CA089-0355-97

COMPANY Stanley, Charles Joseph

FARM Hayes, Barry S.

DATE DRILLED June 1, 1998

NO.

ELEVATION 0'

COUNTY NO. 32712

LOCATION

LATITUDE 41.959418

LONGITUDE -88.401235

COUNTY Kane

API# 1208932712 00

11-40N-7E