

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
sandy brown clay	3	9
medium gravel w/clay	9	50
limestone gray	50	140

Total Depth **140**

Casing: 5" SDR 21 PVC from -1' to 53'

Grout: BENTONITE 20% from 0 to 0

Water from limestone at 100' to 125'

Static level 45' below casing top which is 1' above GL

Pumping level 90' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 105' on 3/20/2002, with a capacity of 10 gpm

Remarks: driller's est well yield 20 gpm

Owner Address: 1112 S. Batavia Ave. Batavia, IL

Address of well: same as above

Location source: Location from permit

Permit Date: March 15, 2002

Permit #:

COMPANY Pitz, John W.

FARM Jacobson, Carolyn & Delbert

DATE DRILLED March 15, 2002

NO.

ELEVATION 0'

COUNTY NO. 34506

LOCATION

LATITUDE 41.833687

LONGITUDE -88.315011

COUNTY Kane

API# 1208934506 00

27-39N-8E