

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	18
gravel & sand	18	30
clay	30	123
gravel	123	130

Total Depth **130**

Casing: 5" PVC from 0' to 126'

5.625" SS SCREEN from 126' to 130'

Screen: 4' of 5.625" diameter 25 slot

Grout: WYOBEN 20% from 0 to 80

Water from gravel at 123' to 130'

Static level 40' below casing top which is 1' above GL

Pumping level 80' when pumping at 18 gpm for 12 hr(s)

Permanent pump installed at 120' on 5/23/2003, with a capacity of 18 gpm

Remarks: driller's est well yield 20 gpm

Owner Address: 12555 Farm Hill Dr. Huntley, IL

Address of well: Brier Hill Rd. Huntley, IL Huntley IL

Location source: Location from permit

Permit Date: May 9, 2003

Permit #:

COMPANY Huemann, William F.

FARM Del Webb Communities of IL Inc

DATE DRILLED May 23, 2003

NO.

ELEVATION 0'

COUNTY NO. 35087

LOCATION

LATITUDE 42.152482

LONGITUDE -88.490189

COUNTY Kane

API# 1208935087 00

1-42N-6E