

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand & gravel	0	25
blue clay	25	35
sand & gravel	35	114
broken limestone	114	122
limestone w/streaks of shale	122	300

Total Depth **300**

Casing: 8" A53 STEEL from -2' to 122'

Grout: BENTONITE 20% from 0 to 122

Water from limestone at 122' to 300'

Static level 45' below casing top which is 1' above GL

Pumping level 80' when pumping at 400 gpm for 1 hr(s)

Permanent pump installed at 105' on 9/17/2003, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 400 gpm

Owner Address: Brad Huiner 1271 S. River Batavia, IL

Address of well: Rte. 47 Elburn, IL Elburn IL

Location source: Location from permit

Permit Date: August 15, 2003

Permit #: BB089-0343-03

COMPANY Pitz, John W.

FARM Batavia Concrete, Inc.

DATE DRILLED August 21, 2003

NO.

ELEVATION '

COUNTY NO. 36279

LOCATION

LATITUDE 41.849611

LONGITUDE -88.466581

COUNTY Kane

API# 1208936279 00

20-39N-7E