

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	25
sand, gravel	25	33
clay	33	52
sand, gravel	52	87
peat	87	95
limestone	95	101
limestone w/blue streaks	101	120
gray rock, shale	120	305
limestone	305	635
sandstone	635	785

Total Depth **785**

Casing: 10" STEEL from -2' to 101'

6" STEEL from 20' to 386'

Grout: BENTONITE from 0 to 101

Water from sandstone at 635' to 785'

Static level 380' below casing top which is 2' above GL

Pumping level 525' when pumping at 150 gpm for 2 hr(s)

Permanent pump installed at 609' on 1/31/2007, with a capacity of 140 gpm

Remarks: Driller's Estimated Well Yield 150 gpm

Owner Address: 37W130 Crane Road St. Charles, IL

Address of well: 36W925 Red Gate Road St. Charles, IL St. Charles IL

Location source: Location from permit

Permit Date: May 19, 2006

Permit #: SC089-0084-06

COMPANY John A. Jablonski

FARM Hosanna Lutheran Church

DATE DRILLED December 30, 2006

NO. 1

ELEVATION '

COUNTY NO. 36338

LOCATION

LATITUDE 41.953361

LONGITUDE -88.331892

COUNTY Kane

API# 1208936338 00

16-40N-8E