

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
clay	2	10
sand - gravel	10	82
rock	82	180

Total Depth **180**

Casing: 6" PVC SDR 21 from ' to '

Grout: BENTONITE from 0 to 90

Water from rock at 110' to 180'

Static level 20' below casing top which is 1' above GL

Pumping level 50' when pumping at 30 gpm for 2 hr(s)

Permanent pump installed at 140' on 7/5/2010, with a capacity of 30 gpm

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 1N318 Watson Rd Maple Park, IL

Address of well: 1N145 Watson Rd Maple Park, IL Maple Park IL

Location source: Location from permit

Permit Date: June 18, 2010

Permit #: KA089-0053-10

COMPANY Ward, Delbert G.

FARM Kuipers, Wade & Kim

DATE DRILLED June 25, 2010

NO.

ELEVATION '

COUNTY NO. 36630

LOCATION

LATITUDE 41.882567

LONGITUDE -88.557617

COUNTY Kane

API# 1208936630 00

4-39N-6E