

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	15
gray clay	15	70
gravel	70	80
gray clay with gravel	80	100
white rock	100	150
gray rock with shale	150	330
limestone	330	460

Total Depth **460**

Casing: 6" PVC from 0' to 105'
 4.5" PVC from 10' to 440'

Grout: BENTONITE from 0 to 80

Water from limestone at 83' to 300'

Static level 80' below casing top which is 1' above GL

Pumping level 225' when pumping at 25 gpm for 2 hr(s)

Permanent pump installed at 300' on 11/23/2009, with a capacity of 25 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 505 North Lake Shore Drive Apt 3302 Chicago, IL

Address of well: 34W556 Country Club Rd Wayne, IL Wayne IL

Location source: Location from permit

Permit Date: October 15, 2009 **Permit #:** SC089-0004-09

COMPANY Wellendorf, Rodney

FARM Dodrill, Douglas

DATE DRILLED November 13, 2009 **NO.**

ELEVATION 851' **COUNTY NO.** 36673

LOCATION

LATITUDE 41.938917 **LONGITUDE** -88.292833

COUNTY Kane **API#** 1208936673 00 **23-40N-8E**