

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well, Plugged	Top	Bottom
topsoil	0	1
fill (sandy clay & gravel)	1	12
gravelly clay black	12	22
sand gravel clay	22	28
coarse sand & gravel	28	44

Total Depth **44**

Casing: 12" STEEL from 2' to 30'

12" SCREEN from 30' to 42'

Screen: 12' of 12" diameter slot

Grout: PEA GRAVEL from 12 to 44

Water from gravel at 22' to 44'

Static level 19' below casing top which is ' above GL

Remarks: temp dewat, sealed 12/9/2009

Owner Address: 3826 Karl Madsen Drive St. Charles, IL

Address of well: same as above

Add'l loc info: Subdivision: 911 Center

Location source: Location from permit

Permit Date: September 23, 2009

Permit #: SC089-0108-09

COMPANY Kerry, Charles M.

FARM Tri-Com Dispatch Center

DATE DRILLED September 30, 2009

NO. 1

ELEVATION '

COUNTY NO. 36681

LOCATION

LATITUDE 41.903506

LONGITUDE -88.367918

COUNTY Kane

API# 1208936681 00

31-40N-8E