

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well, Plugged	Top	Bottom
topsoil	0	1
fill (sandy clay & gravel)	1	12
gravelly sand silt	12	29
coarse sand gravel	29	41

Total Depth **41**

Casing: 12" SCREEN from 28' to 40'

12" STEEL from 2' to 28'

Screen: 12' of 12" diameter slot

Grout: PEA GRAVEL from 13 to 41

Water from gravel at 12' to 41'

Remarks: temp dewat; sealed 12/9/2009

Owner Address: 3826 Karl Madsen Drive St. Charles, IL

Address of well: same as above

Add'l loc info: Subdivision: 911 Center

Location source: Location from permit

Permit Date: September 23, 2009 **Permit #:** SC089-0108-09

COMPANY Kerry, Charles M.

FARM Tri-Com Dispatch Center

DATE DRILLED September 29, 2009 **NO.** 4

ELEVATION ' **COUNTY NO.** 36688

LOCATION

LATITUDE 41.903506 **LONGITUDE** -88.367918

COUNTY Kane **API#** 1208936688 00 **31-40N-8E**