

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
bank run	0	3
sand yellow	3	15
hard pan clay & stones	15	126
yellow clay stones	126	139
broken yellow lime	139	158
shale gray streaks limey	158	205

Total Depth **205**

Casing: 5" A53 120 from -12' to 159'

Grout: GRANULATED from 0 to 158

Water from limestone at 159' to 205'

Static level 138' below casing top which is 1' above GL

Pumping level 220' when pumping at 10 gpm for 3 hr(s)

Permanent pump installed at 210' on , with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 10 gpm

Owner Address: 0S581 Skyline Dr Batavia, IL

Address of well: 4N360 Pheasant Run Dr St Charles, IL St Charles IL

Location source: Location from the driller

Permit Date: March 9, 2022

Permit #: SC089-0015-22

COMPANY Weirich, William Theodore

FARM Davis, Len

DATE DRILLED October 15, 2022

NO.

ELEVATION '

COUNTY NO. 37568

LOCATION

LATITUDE 41.932572

LONGITUDE -88.370504

COUNTY Kane

API# 1208937568 00

19-40N-8E