

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay & stones	0	75
sandy clay & gravel	75	85
clay & stones	85	100
sandy clay & gravel	100	140
clay & stones	140	160
limestone & shale	160	240
TD limestone GP	240	270

Total Depth **270**

Casing: 6" A53B T/C from -1' to 164'

Grout: BENTONITE from 0 to 164

Water from clay & stones at 35' to 250'

Static level 35' below casing top which is 1' above GL

Pumping level 35' when pumping at 7 gpm for 4 hr(s)

Permanent pump installed at 240' on 10/2/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 7 gpm

Owner Address: 3N026 Howard Rd Maple Park, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: September 9, 2023 **Permit #:** VI089-0127-23

COMPANY Matt Liberg

FARM Pakenas, James & Cyntiha

DATE DRILLED September 26, 2023 **NO.**

ELEVATION ' **COUNTY NO.** 37615

LOCATION

LATITUDE 41.909730 **LONGITUDE** -88.576976

COUNTY Kane **API#** 1208937615 00 **29-40N-6E**