

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sandy clay	0	6
unknown	6	80

Total Depth 80

Casing: 4" RAISE WELL TO CODE from 0' to 6'

Water from limestone at 60' to 75'

Static level 30' below casing top which is 1' above GL

Pumping level 50' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 65' on 5/1/2013, with a capacity of 10 gpm

Owner Address: 7 Weft Rd. Kankakee, IL

Address of well: 4988 E 3500 S. Road Saint Anne, IL Saint Anne IL

Location source: Global Positioning System verified

Verified by: VJA on 1/7/2016

Permit Date: February 8, 2013

Permit #: 091-003-13

COMPANY Mills, Wayne

FARM Colbert, Mike & Alice

DATE DRILLED May 1, 2013

NO.

ELEVATION '

COUNTY NO. 27747

LOCATION

LATITUDE 41.067500

LONGITUDE -87.772611

COUNTY Kankakee

API# 1209127747 00

24-30N-13W