

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
clay	2	26
broken limestone	26	28
limestone	28	120

Total Depth **120**

Casing: 5" SDR 21 PVC from -2' to 41'

Grout: BENSEAL from 0 to 40

Water from limestone at 41' to 120'

Static level 16' below casing top which is 2' above GL

Pumping level 22' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 100' on 12/2/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 8565 Chicago Ave Kankakee, IL

Address of well: 7320 Rd 2500 E St Anne, IL St Anne IL

Location source: Location from the driller

Permit Date: October 12, 2023

Permit #: 091-036-23

COMPANY Reiners, Lynn

FARM Froning, Dave

DATE DRILLED November 22, 2023

NO.

ELEVATION '

COUNTY NO. 28406

LOCATION

LATITUDE 41.014853

LONGITUDE -87.820443

COUNTY Kankakee

API# 1209128406 00

10-29N-13W