

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	78
brown shale	78	139
dolomite	139	300

Total Depth **300**

Casing: 5" PVC from -2' to 141'

Grout: MUD from 0 to 141

Size hole below casing: 5"

Water from limestone at 141' to 300'

Static level 155' below casing top which is 2' above GL

Pumping level 120' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 120' on 11/5/1992, with a capacity of 10 gpm

Owner Address: 514 N. Lake St. Aurora, IL

Add'l loc info: Lot: #14 Subdivision: Fox Glen

Location source: Location from permit

Permit Date: October 7, 1992

Permit #:

COMPANY Neeley, Harry C.

FARM Stewart, Chuck

DATE DRILLED October 9, 1992

NO. 1

ELEVATION 653' GL

COUNTY NO. 22710

LOCATION

LATITUDE 41.603993

LONGITUDE -88.484856

COUNTY Kendall

API# 1209322710 00

7-36N-7E