

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
clay	1	40
sand gravel	40	55
clay	55	150
shale	150	230
rock	230	570
sandstone	570	700

Total Depth **700**

Casing: 6" PVC SDR 17 from 0' to 233'

Grout: BENTONITE from 0 to 233

Water from sandstone at 620' to 700'

Static level 420' below casing top which is 1' above GL

Pumping level 525' when pumping at 50 gpm for 2 hr(s)

Permanent pump installed at 525' on 5/16/2008, with a capacity of 22 gpm

Remarks: Driller's Estimated Well Yield 50+ gpm

Owner Address: PO Box 280 Oswego, IL

Address of well: Henneberry Pkwy Oswego, IL Oswego IL

Add'l loc info: Lot: 34 Subdivision: Henneberry

Location source: Location from permit

Permit Date: February 19, 2008

Permit #: 093-012-08

COMPANY Brown, Darwin

FARM Pacific Homes, Inc

DATE DRILLED May 12, 2008

NO.

ELEVATION '

COUNTY NO. 24912

LOCATION

LATITUDE 41.626950

LONGITUDE -88.343717

COUNTY Kendall

API# 1209324912 00

6-36N-8E