

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black soil	0	3
clay soft squeezing	3	25
sandstone	25	27
rock & dk gry blk shale strks water @ 36	27	50

Total Depth **50**

Casing: 6" PLASTIC SDR 26 SLOT from 10' to 50'
 8" STEEL SCH 40 from -2' to 26'

Grout: NEAT CEMENT from 4 to 16

Water from Pennsylvanian system at 36' to '

Static level 6' below casing top which is 2' above GL

Pumping level 18' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 35' on 6/30/1995, with a capacity of 10 gpm

Owner Address: 2159 IL Rt. #8 Box #277 Yates City, IL

Location source: Location from permit

Permit Date: May 26, 1995

Permit #:

COMPANY Norton, William H.

FARM Cross Roads Development

DATE DRILLED June 30, 1995

NO. 1

ELEVATION 0'

COUNTY NO. 23024

LOCATION

LATITUDE 40.779553

LONGITUDE -90.032704

COUNTY Knox

API# 1209523024 00

10-9N-4E