

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	7
yellow clay	7	43
shale	43	63
broken lime & shale	63	78

Total Depth

78

Casing: 6" 280 WALL STEEL from 0' to 63'
4.5" PVC from 57' to 78'

Grout: NATURAL CLAY from 0 to 20

Water from rock at 63' to 78'

Static level 23' below casing top which is 2' above GL

Pumping level 60' when pumping at 5 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: 1228 Steakhouse Rd. Knoxville, IL

Address of well: same as above

Location source: Location from permit

Permit Date: August 18, 2000

Permit #:

COMPANY Hunter, Dennis

FARM Hanson, Dale

DATE DRILLED October 11, 2000

NO.

ELEVATION 0'

COUNTY NO. 23365

LOCATION

LATITUDE 40.893565

LONGITUDE -90.261935

COUNTY Knox

API# 1209523365 00

34-11N-2E