

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	9
sand	9	75
blue clay	75	115
sand & gravel	115	210
hardpan	210	226
coarse gravel	226	232

Total Depth **232**

Casing: 5" GALV 15# from 0' to 232'

Water from gravel at 0' to 0'

Static level 60' below casing top which is 1' above GL

Pumping level 60' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Driller's Log filed.

Owner Address: Tamarack Dr. Wauconda, IL

Address of well:

Location source: Location from permit

Permit Date: June 11, 1970

Permit #:

COMPANY Snelton, Peter

FARM Glisson, Fred Builder

DATE DRILLED June 20, 1970

NO.

ELEVATION 0'

COUNTY NO. 01493

LOCATION

LATITUDE 42.251064

LONGITUDE -88.133882

COUNTY Lake

API# 1209701493 00

36-44N-9E