

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	17
blue clay	17	51
sandy clay	51	90
clay	90	123
sand	123	136

Total Depth **136**

Casing: 5" GALV T&C 14.81#/' from 0' to 130'

Screen: 3' of 5" diameter 12 slot

Size hole below casing: 5"

Water from sand at 123' to 136'

Static level 87' below casing top which is 1' above GL

Pumping level 97' when pumping at 23 gpm for 3 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Remarks: Sub. pump set at 105 + 10'

Driller's Log filed.

Owner Address: % Gary Rechtfertig 504 Northgate Lindenhurst, IL

Address of well:

Location source: Digital Orthophoto Quad

Verified by: VJA on 7/20/0004

Permit Date: June 21, 1977

Permit #: 62374

COMPANY Hoover, L. R.

FARM Calvary Temple Assembly

DATE DRILLED June 16, 1977

NO.

ELEVATION 0'

COUNTY NO. 25379

LOCATION

LATITUDE 42.397976

LONGITUDE -88.085906

COUNTY Lake

API# 1209725379 00

8-45N-10E