

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil & fill	0	10
gray clay hard	10	40
dirty sand	40	57
red clay, smooth	57	90
gravelly clay	90	100
clean sand to nice gravel	100	107

Total Depth **107**

Casing: 4" A53 & GALV STEEL from 0' to 107'

Grout: CLAY SLURRY from 0 to 20

Water from drift at 107' to '

Pumping level 5' when pumping at 2 gpm for 2 hr(s)

Permanent pump installed at 20' on 7/23/1994, with a capacity of 10 gpm

Remarks: static level 4' above ground

Address of well: 42469 N. Park Ave. Antioch, IL Antioch IL

Location source: Location from the driller

Permit Date: July 1, 1994

Permit #:

COMPANY Wertz, Charles L.

FARM Lettner, Jim

DATE DRILLED July 21, 1994

NO.

ELEVATION 738' GL

COUNTY NO. 27594

LOCATION

LATITUDE 42.480219

LONGITUDE -88.168249

COUNTY Lake

API# 1209727594 00

10-46N-9E