

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	20
blue clay	20	110
sand	110	118

Total Depth **118**

Casing: 4" GALV ASTM A53B 11/' from 0' to 113'

Screen: 5' of 3" diameter 12 slot

Grout: BENTONITE from 0 to 110

Water from sand at 110' to 118'

Static level 5' below casing top which is 1' above GL

Pumping level 90' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 90' on 10/9/2001, with a capacity of 10 gpm

Remarks: driller's estimated well yield 10 gpm

Owner Address: % Christine Welsch PO Box 72 Fox Lake, IL

Address of well: 26349 W. Blackhawk Ave. Ingleside, IL Ingleside IL

Add'l loc info: Lot: 62 Subdivision: Lindenhurst 3rd

Location source: Location from permit

Permit Date: September 20, 2001 **Permit #:**

COMPANY Madsen, Charles E.

FARM CJW Development Co.

DATE DRILLED October 4, 2001 **NO.**

ELEVATION 0' **COUNTY NO.** 28334

LOCATION

LATITUDE 42.380385 **LONGITUDE** -88.145947

COUNTY Lake **API#** 1209728334 00 **14-45N-9E**