

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil-black	0	2
clay-yellow-hard	2	25
sand-yellow-coarse	25	36
clay-grey-medium	36	49
sand-grey-fine	49	57
clay-grey-soft	57	78
sand-grey-fine	78	84

Total Depth

84

Casing: 4" GALV 11# from 0' to 80'

Screen: 7' of 3" diameter 10 slot

Size hole below casing: 3"

Water from drift at 80' to 84'

Static level 20' below casing top which is 1' above GL

Pumping level 30' when pumping at 15 gpm for 12 hr(s)

Permanent pump installed at 50' on 4/10/1989, with a capacity of 10 gpm

Owner Address: 403 Helendale Ave. Ingleside, IL

Location source: Location from permit

Permit Date: March 13, 1979

Permit #: 83935

COMPANY Carlson, William L.

FARM Weishaar, J.

DATE DRILLED April 10, 1989

NO.

ELEVATION 0'

COUNTY NO. 32536

LOCATION 550'N line, 1300'E line of

LATITUDE 42.385180

LONGITUDE -88.144643

COUNTY Lake

API# 1209732536 00

14-45N-9E