

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	15
sand	15	50
gravel	50	70
sand & gravel	70	108

Total Depth **108**

Casing: 5" SDR 21-200# PVC from 0' to 105'

4" SCREEN PKG from 102' to 108'

Screen: 3' of 4" diameter 30 slot

Grout: SLURRY from 0 to 105

Size hole below casing: 4"

Water from drift at 105' to 108'

Static level 50' below casing top which is 0' above GL

Pumping level 80' when pumping at 0 gpm for 24 hr(s)

Permanent pump installed at 80' on 7/26/1994, with a capacity of 10 gpm

Remarks: Elevation updated from other_header-ABL

Owner Address: 195 Foxfire Dr. Lake Zurich, IL

Address of well: 177 Willow Road. Ingleside, IL. Ingleside IL

Add'l loc info: Lot: 15 Subdivision: Oak Crest

Location source: Tax record verified

Verified by: BL on 5/15/2001

Permit Date: July 7, 1994

Permit #: WW 94-08-0627

COMPANY Hutchings, James A.

FARM FoxFire Construction Associate

DATE DRILLED July 21, 1994

NO.

ELEVATION 806' GL

COUNTY NO. 38282

LOCATION

LATITUDE 42.375163

LONGITUDE -88.168210

COUNTY Lake

API# 1209738282 00

15-45N-9E