

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	15
gritty clay	15	40
smooth blue clay	40	70
gray soft clay	70	75
sand fine to coarse	75	87

Total Depth

87

Casing: 4" 11# GALV from 0' to 84'

Screen: 4' of 3" diameter 15 slot

Grout: CLAY SLURRY from 0 to 20

Water from drift at 87' to '

Static level 21' below casing top which is 1' above GL

Pumping level 25' when pumping at 0 gpm for 3 hr(s)

Permanent pump installed at 35' on 8/26/1994, with a capacity of 10 gpm

Remarks: Elevation updated from other_header-ABL

Owner Address: 42377 N. Woods Dr. Antioch, IL

Address of well: same as above

Add'l loc info: Lot: 16-17 Subdivision: Felters S.View

Location source: Tax record verified

Verified by: BL on 5/15/2001 11:07:04 AM

Permit Date: August 9, 1994

Permit #:

COMPANY Wertz, Charles L.

FARM Reid, David

DATE DRILLED August 26, 1994

NO. 1

ELEVATION 760' GL

COUNTY NO. 38480

LOCATION

LATITUDE 42.479647

LONGITUDE -88.122127

COUNTY Lake

API# 1209738480 00

12-46N-9E