

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	4
clay, blue, smooth	4	25
clay, gray, sandy	25	60
sand, gray, silty	60	65
sand, red, fine	65	71

Total Depth

71

Casing: 4" GALV STEEL from -1' to 67'

3" STAINLESS SCREEN from 67' to 71'

Screen: 4' of 3" diameter 10 slot

Grout: CASING SEAL from to

Water from unconsolidated at 67' to 71'

Static level 7' below casing top which is 1' above GL

Pumping level 8' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 40' on 3/16/2004, with a capacity of 10 gpm

Remarks: gamma file: Elime.aa0/driller est. 25gpm

Owner Address: 424 Lake St. Antioch, IL

Address of well: 41179 Elime Rd. Antioch, IL Antioch IL

Add'l loc info: Lot: 29 Subdivision: Louis Forbrich's

Location source: Global Positioning System verified

Verified by: ADW on 10/8/2003

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Natural Gamma Log

[GET FILE](#)

Related File - Unknown File Type

Permit Date: August 21, 2003

Permit #: 097-01-0657-03

COMPANY Blake, William D.

FARM Danielewicz, Brian/Elime.aa0

DATE DRILLED October 1, 2003

NO.

ELEVATION 739' GP

COUNTY NO. 48394

LOCATION

LATITUDE 42.461485

LONGITUDE -88.142278

COUNTY Lake

API# 1209748394 00

14-46N-9E