

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand & gravel	0	81
blue clay	81	103
sand & gravel	103	124

Total Depth **124**

Casing: 5" PVC from 0' to 121'

5" SS ASTM D-2241 from 121' to 124'

Grout: BENTONITE from 0 to 120

Water from sand & gravel at 121' to 124'

Static level 5' below casing top which is 1' above GL

Pumping level 10' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 40' on 11/28/2005, with a capacity of 10 gpm

Remarks: gamma

Owner Address: 102 Quail Path Ingleside, IL

Address of well: 28650 W. Greenleaf Fox Lake, IL Fox Lake IL

Location source: Field verified

Verified by: DW on 11/22/2005

Permit Date: September 19, 2005

Permit #: 097-140029-05

COMPANY Snelten, Richard Charles

FARM Glashegel, Glen

DATE DRILLED November 10, 2005

NO.

ELEVATION 741' GL

COUNTY NO. 50036

LOCATION

LATITUDE 42.421842

LONGITUDE -88.192424

COUNTY Lake

API# 1209750036 00

33-46N-9E