

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow, clay	0	18
clay, gray	18	75
sand, fine silty, gray	75	81
sand, coarse, red	81	88

Total Depth **88**

Casing: 4" GALV STEEL from -1' to 84'
 3" STAINLESS from 84' to 88'

Screen: 4' of 3" diameter slot

Grout: BENSEAL from to

Water from unconsolidated at 84' to 88'

Static level 18' below casing top which is 1' above GL

Pumping level 19' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 40' on 9/15/2006, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 42478 N. Woodbine Ave. Antioch, IL

Address of well: same as above

Add'l loc info: Lot: 10, 11 Subdivision: Woodbine Park

Location source: Aerial Photograph verified

Verified by: DRS on 2/2/2007

Imaged Log viewing help: New users please read this.

GET FILE

Related File - Unknown File Type

Permit Date: August 10, 2006

Permit #: 097-147649-06

COMPANY Wayne D. Blake

FARM Grogan, Troy

DATE DRILLED August 22, 2006

NO.

ELEVATION '

COUNTY NO. 50401

LOCATION

LATITUDE 42.480462

LONGITUDE -88.143816

COUNTY Lake

API# 1209750401 00

11-46N-9E