

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand, yellow	0	25
sand, gray	25	65
sand, red	65	71

Total Depth

71

Casing: 4" GALV STEEL from -1' to 67'

3" STAINLESS SCREEN from 67' to 71'

Screen: 4' of 3" diameter 15 slot

Grout: BENSEAL from 0 to 67

Water from unconsolidated at 67' to 71'

Static level 10' below casing top which is 1' above GL

Pumping level 11' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 40' on 10/6/2006, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 909 E. Morris Dr. Palatine, IL

Address of well: 35247 N. Shoreline Dr. Ingleside, IL Ingleside IL

Location source: Digital Orthophoto Quad

Verified by: VJA on 2/5/2007

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: September 25, 2006

Permit #: 097-148592-06

COMPANY Wayne D. Blake

FARM Palanos, Matt

DATE DRILLED September 28, 2006

NO.

ELEVATION '

COUNTY NO. 50467

LOCATION

LATITUDE 42.375926

LONGITUDE -88.151336

COUNTY Lake

API# 1209750467 00

14-45N-9E