

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand	0	5
clay, yellow	5	20
clay, gray	20	85
sand, red, coarse	85	92

Total Depth

92

Casing: 4" GALV STEEL from -1' to 88'
3" STAINLESS SCREEN from 88' to 92'

Screen: 4' of 3" diameter 12 slot

Grout: BENSEAL from to

Water from unconsolidated at 88' to 92'

Static level 17' below casing top which is 1' above GL

Pumping level 18' when pumping at 12 gpm for 2 hr(s)

Permanent pump installed at 40' on 9/20/2006, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 1036 N. Randall Rd. Aurora, IL

Address of well: 42417 N. Orchard St. Antioch, IL Antioch IL

Add'l loc info: Lot: 7 Subdivision: Hillewood

Location source: Digital Orthophoto Quad

Verified by: VJA on 2/8/2007

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: August 11, 2006

Permit #: 097-147357-06

COMPANY Wayne D. Blake

FARM Hill, Worth

DATE DRILLED August 21, 2006

NO.

ELEVATION '

COUNTY NO. 50492

LOCATION

LATITUDE 42.480055

LONGITUDE -88.132634

COUNTY Lake

API# 1209750492 00

12-46N-9E