

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
clay brown	1	30
gray clay	30	105
sandy clay	105	165
sand & gravel	165	177

Total Depth **177**

Casing: 5" PVC from -1' to 174'
 4" SS SCREEN from 174' to 177'

Screen: 3' of 4" diameter 30 slot

Grout: QUIK GROUT from 0 to 90
 PEA GRAVEL from 165 to 177

Water from gravel at 165' to 177'

Static level 35' below casing top which is 1' above GL

Pumping level 60' when pumping at 10 gpm for 24 hr(s)

Permanent pump installed at 105' on 3/19/2008, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 10 gpm

Owner Address: 7306 Hawthorn Ln. Ingleside, IL

Address of well: 26048 W. Larkin Ln. Ingleside, IL Ingleside IL

Add'l loc info: Lot: 37 Subdivision: Emerald Shores

Location source: Global Positioning System verified

Verified by: VJA on 10/9/2008

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: February 4, 2008

Permit #: 097-162990-08

COMPANY H2o Well & Pump Co.

FARM Bujak, Leo

DATE DRILLED March 14, 2008

NO. 1

ELEVATION '

COUNTY NO. 51420

LOCATION

LATITUDE 42.372778

LONGITUDE -88.141194

COUNTY Lake

API# 1209751420 00

14-45N-9E