

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
sand	1	15
blue clay	15	65
sandy clay	65	75
fine sand	75	211
sand	211	212

Total Depth **212**

Casing: 4" GALV STEEL from 0' to 212'

Grout: GRANULAR BENTONITE from 0 to 212

Water from sand & gravel at 212' to 212'

Static level 7' below casing top which is 2' above GL

Pumping level 10' when pumping at 20 gpm for 4 hr(s)

Permanent pump installed at 30' on 10/17/2008, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 39410 Summerside Dr Antioch, IL

Address of well: same as above

Add'l loc info: Lot: 68 Subdivision: Resthaven

Location source: Location from permit

Verified by: VJA on 6/30/2010

Permit Date: September 5, 2008 **Permit #:** 097-168583-08

COMPANY Glenn, James E.

FARM Ramirez, Joseph

DATE DRILLED October 8, 2008

NO.

ELEVATION '

COUNTY NO. 51797

LOCATION

LATITUDE 42.435778

LONGITUDE -88.131613

COUNTY Lake

API# 1209751797 00

25-46N-9E