

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	10
blue clay	10	130
sand & light gravel	130	142

Total Depth **142**

Casing: 5" SDR 21 PVC from -1' to 135'
 4" STAINLESS STL SCREEN from 135' to 142'

Screen: 7' of 4" diameter 10 slot

Grout: BENTONITE from 0 to 135

Water from sand & light gravel at 130' to 142'

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 26675 W. Michigan Blvd Antioch, IL

Address of well: 41482 N. Lakeview Terrace Antioch, IL Antioch IL

Add'l loc info: Lot: 1-4 Subdivision: Antioch Hills

Location source: Location from permit

Verified by: VJA on 2/14/2011

Permit Date: December 10, 2009 **Permit #:** 097-178359-09

COMPANY Gaffke, George E.

FARM Taylor, Robert D.

DATE DRILLED February 12, 2010 **NO.**

ELEVATION ' **COUNTY NO.** 51851

LOCATION

LATITUDE 42.466050 **LONGITUDE** -88.095033

COUNTY Lake **API#** 1209751851 00 **17-46N-10E**