

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	7
sandy clay	7	19
blue clay	19	80
sand	80	87

Total Depth **87**

Casing: 4" GALV. STEEL SCH 40 from 0' to 83'

3.75" STAINLESS STL SCREEN from 83' to 87'

Screen: 4' of 3.75" diameter 10 slot

Grout: CLAY SLURRY from 0 to 75

Water from sand at 80' to 87'

Static level 8' below casing top which is 1' above GL

Pumping level 10' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 30' on 4/1/2011, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 42721 N. Park Antioch, IL

Address of well: 40898 N. Park Ave. Antioch, IL Antioch IL

Add'l loc info: Lot: 18 Subdivision: Woodland Park

Location source: Global Positioning System verified

Verified by: VJA on 4/24/2012

Permit Date: March 30, 2011

Permit #: 097-183866-11

COMPANY Wauchholder Well Drilling

FARM Borys, Danny

DATE DRILLED March 31, 2011

NO. 1

ELEVATION '

COUNTY NO. 51950

LOCATION

LATITUDE 42.457290

LONGITUDE -88.130470

COUNTY Lake

API# 1209751950 00

24-46N-9E