

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black dirt	0	8
clay	8	21
sand	21	26
clay	26	56
coarse sand & gravel	56	65

Total Depth

65

Casing: 4" ASTM A53B from 0' to 61'

4" PVC SCREEN from 62' to 65'

Screen: 3' of 4" diameter 12 slot

Grout: GRAN BENTONITE from to

Water from coarse sand & gravel at 57' to 65'

Static level 5' below casing top which is 3' above GL

Pumping level 30' when pumping at 14 gpm for 3 hr(s)

Permanent pump installed at 30' on 1/11/2021, with a capacity of 14 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 26137 W Mary Ann Rd Antioch, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: January 6, 2021

Permit #: 043753-2021

COMPANY Madsen, Michael A.

FARM Lehmann, Todd

DATE DRILLED January 8, 2021

NO.

ELEVATION '

COUNTY NO. 53703

LOCATION

LATITUDE 42.459990

LONGITUDE -88.143980

COUNTY Lake

API# 1209753703 00

14-46N-9E