

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	13
blue clay	13	150
fine gray sand	150	187
gravel sand clay mix	187	231
limestone	231	235

Total Depth

235

Casing: 5" PVC SOLVENT WELD from 0' to 231'

5" ROCK ASTM 2241 from 231' to 235'

Grout: BENTONITE from 0 to 231

Water from limestone at 231' to 235'

Static level 96' below casing top which is 1' above GL

Pumping level 160' when pumping at 12 gpm for 2 hr(s)

Permanent pump installed at 160' on 4/15/2021, with a capacity of 12 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: PO Box 6123 Wauconda, IL

Address of well: 23927 Lakeside Dr Lake Zurich, IL Lake Zurich IL

Location source: Global Positioning System verified

Verified by: VJA on 2/2/2022

Permit Date: July 17, 2020

Permit #: WW036580-2020

COMPANY Snelten, Greg

FARM Zizzo, Daniel

DATE DRILLED April 7, 2021

NO.

ELEVATION '

COUNTY NO. 53772

LOCATION

LATITUDE 42.210853

LONGITUDE -88.053011

COUNTY Lake

API# 1209753772 00

15-43N-10E