

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand	0	8
gravel	8	28
sand	28	96
gravel	96	118

Total Depth **118**

Casing: 5" PVC GLUED from 0' to 118'
5" SCREEN from 114' to 118'

Screen: 4' of 5" diameter 15 slot

Grout: GRAN BENT from 0 to 108

Water from gravel at 114' to 118'

Static level 35' below casing top which is 2' above GL

Pumping level 100' when pumping at 8 gpm for 12 hr(s)

Permanent pump installed at 100' on 11/7/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 11 gpm

Address of well: 38219 2nd Ave Spring Grove, IL Spring Grove IL

Location source: Global Positioning System verified

Verified by: VJA on 7/1/2024

Permit Date: September 25, 2023 **Permit #:** 097-075152-23

COMPANY Snelten, Jeffrey

FARM Luedtka, Hanes

DATE DRILLED November 3, 2023 **NO.**

ELEVATION ' **COUNTY NO.** 54098

LOCATION

LATITUDE 42.418736 **LONGITUDE** -88.173334

COUNTY Lake **API#** 1209754098 00 **34-46N-9E**