

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	19
stoney gray clay	19	60
sandy gray clay	60	130
hard pan stone	130	145
hard pan gray	145	200
hard pan gray	200	238
gravel	238	241
limestone	241	270

Total Depth **270**

Casing: 5" ASTM A 53B from 0' to 240'

Grout: GRAN BENT from 0 to 20

Water from limestone at 240' to 270'

Static level 130' below casing top which is 1' above GL

Pumping level 230' when pumping at 3 gpm for 24 hr(s)

Permanent pump installed at 260' on 5/28/2023, with a capacity of 7 gpm

Remarks: Driller's Estimated Well Yield 3 gpm

Address of well: 13305 Greenview Dr Wadsworth, IL Wadsworth IL

Location source: Global Positioning System verified

Verified by: VJA on 7/1/2024

Permit Date: May 16, 2023

Permit #: 097-68510-23

COMPANY Boyce, Kenneth D.

FARM Coletta, Tony

DATE DRILLED May 20, 2023

NO.

ELEVATION '

COUNTY NO. 54100

LOCATION

LATITUDE 42.452370

LONGITUDE -87.890230

COUNTY Lake

API# 1209754100 00

24-46N-11E