

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay sandy yellow	0	25
clay gray sandy	25	80
sand gray silty	80	88
sand red coarse	88	95

Total Depth **95**

Casing: 4" steel tc from -1' to 91'
 3" screen from 91' to 95'

Screen: 4' of 30" diameter 12 slot

Grout: CETCO CRUMBLES from to

Water from unconsolidated at 91' to '

Static level 25' below casing top which is 1' above GL

Pumping level 27' when pumping at 15 gpm for hr(s)

Permanent pump installed at 40' on 9/9/2022, with a capacity of 10 gpm

Remarks:

Owner Address: 40488 N South Newport Dr Antioch, IL

Address of well: 40536 N Newport Dr Antioch IL

Add'l loc info: Lot: 35 Subdivision: Newport Cove

Location source: Global Positioning System verified

Verified by: VJA on 11/1/2024

Permit Date: September 22, 2021 **Permit #:** 097-051631

COMPANY Blake, Wayne D.

FARM Tauke, Sue

DATE DRILLED June 21, 2022

NO.

ELEVATION '

COUNTY NO. 54112

LOCATION

LATITUDE 42.452550

LONGITUDE -88.137640

COUNTY Lake

API# 1209754112 00

24-46N-9E