

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
drift	0	63
limestone	63	74
sandstone	74	110

Total Depth **110**

Size hole below casing: 5"

Water from sandstone at 74' to 110'

Static level 20' below casing top which is 1' above GL

Pumping level 21' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 60' on 4/5/1987, with a capacity of 10 gpm

Owner Address: R. R. #3 Earlville, IL

Location source: Location from permit

Permit Date: December 30, 1986 **Permit #:** 128831

COMPANY Snelten, Arthur Charles

FARM Whittaker, Wes

DATE DRILLED April 4, 1987

NO. 1

ELEVATION 0'

COUNTY NO. 23943

LOCATION 50'S line, 100'E line of SW SE SW

LATITUDE 41.585567

LONGITUDE -88.907353

COUNTY LaSalle

API# 1209923943 00

17-36N-3E