

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	8
gravel	8	20
sandstone	20	110

Total Depth **110**

Casing: 5" PVC 250# from 0' to 40'

5" PVC 200# from 40' to 50'

Grout: CUTTINGS from 0 to 50

Size hole below casing: 4.75"

Water from sandstone at 90' to 110'

Static level 50' below casing top which is 1' above GL

Pumping level 80' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 80' on 11/6/1991, with a capacity of 0 gpm

Owner Address: 823 East U.S. R.R. #6 Utica, IL

Location source: Location from permit

Permit Date: May 1, 1991

Permit #: W91-039

COMPANY Strange, Michael K.

FARM Grusk, Robert & Bonnie

DATE DRILLED July 3, 1991

NO.

ELEVATION 0'

COUNTY NO. 24454

LOCATION

LATITUDE 41.361747

LONGITUDE -89.006359

COUNTY LaSalle

API# 1209924454 00

4-33N-2E