

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	20
shale	20	80
shale & sandstone	80	155

Total Depth **155**

Casing: 5" PVC 250 from 0' to 145'

5" PVC 12 SLOT SCREEN from 145' to 155'

Screen: 10' of 5" diameter 12 slot

Grout: CUTTINGS from 0 to 145

Size hole below casing: 5"

Water from sandstone at 145' to 155'

Static level 30' below casing top which is 1' above GL

Pumping level 140' when pumping at 0 gpm for 1 hr(s)

Permanent pump installed at 140' on 9/3/1992, with a capacity of 12 gpm

Owner Address: 1932 N. 2653 Rd. Ottawa, IL

Location source: Location from permit

Permit Date: July 16, 1992

Permit #: W92-121

COMPANY Strange, Michael K.

FARM Bramel, Lewis

DATE DRILLED August 27, 1992

NO.

ELEVATION 0'

COUNTY NO. 24669

LOCATION

LATITUDE 41.316727

LONGITUDE -88.792896

COUNTY LaSalle

API# 1209924669 00

20-33N-4E