

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
clay with gravel	2	92
yellow rock	92	106
soft blue shale	106	110
sandstone	110	160

Total Depth **160**

Casing: 6" PVC from -1' to 97'
4.5" PVC from 80' to 120'

Grout: BENTONITE from 80 to 97

Water from sandstone at 140' to 160'

Static level 9' below casing top which is 1' above GL

Pumping level 37' when pumping at 40 gpm for 2 hr(s)

Permanent pump installed at 80' on 2/2/2007, with a capacity of 33 gpm

Remarks: Driller's Estimated Well Yield 40+ gpm

Owner Address: 4167 E 13th Rd. Earlville, IL

Address of well: same as above

Location source: Location from permit

Permit Date: April 12, 2006

Permit #: 099-080-06

COMPANY Tolley, David F.

FARM Kelly, Julie

DATE DRILLED December 12, 2006

NO.

ELEVATION '

COUNTY NO. 27833

LOCATION

LATITUDE 41.536944

LONGITUDE -88.913611

COUNTY LaSalle

API# 1209927833 00

6-35N-3E