

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay & rocks	0	10
gravel	10	45
clay	45	55
gravel	55	70
shale	70	85
sandstone at	85	85

Total Depth **85**

Casing: 5" PVC SDR 21 from -1' to 94'

Grout: BENTONITE from 0 to 94

Water from sandstone at 94' to 180'

Static level 100' below casing top which is 1' above GL

Pumping level 140' when pumping at 25 gpm for 3 hr(s)

Permanent pump installed at 120' on 4/10/2009, with a capacity of 20 gpm

Owner Address: 14700 S 82nd Ave Orland Park, IL

Address of well: 1971 N 3609 Rd Ottawa, IL Ottawa IL

Location source: Location from permit

Permit Date: August 12, 2008

Permit #: 099-051-W08

COMPANY Lode, Lawrence James

FARM Coghill, Kay

DATE DRILLED March 19, 2009

NO.

ELEVATION '

COUNTY NO. 28090

LOCATION

LATITUDE 41.464280

LONGITUDE -88.770131

COUNTY LaSalle

API# 1209928090 00

33-35N-4E