

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	65
stoney clay	65	105
coarse sand & gravel	105	123

Total Depth **123**

Casing: 5" PVC SDR 21 from 0' to 113'
 5" PVC SCREEN from 113' to 123'

Screen: 10' of 5" diameter 10 slot

Grout: BENTONITE from 0 to 105
 PEA GRAVEL MED from 105 to 123

Water from gravel at 105' to 123'

Static level 25' below casing top which is ' above GL

Pumping level 30' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at ' on 6/4/2009, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 1288 East Highway 52 Ottawa, IL

Address of well: 4782 East 1250th Rd Earlville, IL Earlville IL

Location source: Location from permit

Permit Date: January 12, 2009

Permit #: 099-001-W09

COMPANY Meadow Equipment

FARM Rousonelous, John Jr.

DATE DRILLED January 22, 2009

NO.

ELEVATION '

COUNTY NO. 28099

LOCATION

LATITUDE 41.627513

LONGITUDE -88.935501

COUNTY LaSalle

API# 1209928099 00

6-36N-3E